


FIRE TEST QUALIFICATION CERTIFICATE



Score (Europe) Ltd



Item	Ball Valve, Reduced Bore, End Entry, Flanged
Size	1"
Class	150
Serial no	0057-05
Body material	ASTM A216 WCB
Seat	Virgin PTFE
Manufactured by	Brooksbank Valves Ltd
In accordance with job number	152065 COW
In accordance with drawing number	G0104A01-1-5000 (Issue 01 Dated 02/12/04)

The above valve was tested by Score (Europe) Ltd at their Specialised Valve Research and Test Centre, Cowdenbeath, Scotland and the results have been recorded as a PASS, having complied with the minimum performance requirements stated in specification

API Standard 607, Fourth Edition, May 1993

Test date	30/03/05
Other sizes qualified	NPS ¾", 1", 1¼", 1½"
Other pressure ranges qualified	150, 300

Tested by S Fox / S Penman / G Stephen

Witnessed by W Campbell
Lloyds Register



This certificate must be read in conjunction with the full Score Test Report Number

152065-2