

# FIRE TEST QUALIFICATION CERTIFICATE



Score (Europe) Ltd



Item	Ball Valve
Size	2"
Class	150
Serial No	0334 - 04
Body Material	ASTM A216 WCB
Seat	PTFE
Manufactured by	Brooksbank Valves Ltd
In accordance with job number	145060 COW
In accordance with drawing number	0108A01 - 1 - 5000

The above valve was tested by Score (Europe) Ltd at their Specialised Valve Research and Test Centre, Cowdenbeath, Scotland and the results have been recorded as a PASS, having complied with the minimum performance requirements stated in specification

Test date	API 607 4th Edition, May 1993
Other sizes qualified	24 <sup>th</sup> November 2004
Other pressure ranges qualified	1½", 2", 2½", 3"
	150 , 300

Tested by J. O'Hagan / S. Fox / R. Hepburn



Witnessed by W. Campbell - Lloyds Register

Glasgow Office  
Lloyds Register EMEA  
26 NOV 2004  
G. White  
Brooksbank Valves Ltd  
J. Squires -  
Brooksbank Valves Ltd

This certificate must be read in conjunction with the full Score Test Report Number

145060-1