


FIRE TEST QUALIFICATION CERTIFICATE



Score (Europe) Ltd



Item	Ball Valve, Reduced Bore, End Entry, Flanged
Size	4"
Class	150
Serial no	0061-05
Body material	ASTM A216 WCB
Seat	Virgin PTFE
Manufactured by	Brooksbank Valves Ltd
In accordance with job number	152065 COW
In accordance with drawing number	0116A01-1-5000 (Issue 01 Dated 26/11/04)

The above valve was tested by Score (Europe) Ltd at their Specialised Valve Research and Test Centre, Cowdenbeath, Scotland and the results have been recorded as a PASS, having complied with the minimum performance requirements stated in specification

API Standard 607, Fourth Edition, May 1993

Test date	30/03/05
Other sizes qualified	NPS 3", 4", 5", 6"
Other pressure ranges qualified	150, 300

Tested by S Fox / S Penman / G Stephen

Witnessed by W Campbell
Lloyds Register



This certificate must be read in conjunction with the full Score Test Report Number

152065-4