


FIRE TEST QUALIFICATION CERTIFICATE



Score (Europe) Ltd



Item	Ball Valve, Full Bore, 2 Piece, Flanged
Size	8"
Class	150
Serial no	0135-05
Body material	ASTM A216 WCB
Seat	Virgin PTFE
Manufactured by	Brooksbank Valves Ltd
In accordance with job number	157283 COW
In accordance with drawing number	G0432A01-1-5000 (Dated 31/01/05)

The above valve was tested by **Score (Europe) Ltd** at their **Specialised Valve Research and Test Centre, Cowdenbeath, Scotland** and the results have been recorded as a **PASS**, having complied with the minimum performance requirements stated in **specification**

API Standard 607, Fourth Edition, May 1993

Test date	26/05/05
Other sizes qualified	NPS 6" & larger
Other pressure ranges qualified	150, 300

Tested by S Fox / R Hepburn
G Stephen



Witnessed by W Campbell
Lloyds Register



W Campbell
19 JUN 2005

This certificate must be read in conjunction with the full
Score Test Report Number

157283-3